



Lorain Fire Department
Fire Prevention Bureau
1350 Broadway
Lorain, OH 44052
440.204.2222

FLAMMABLE & COMBUSTIBLE LIQUID – ABOVE GROUND STORAGE TANKS

PLAN SUBMITTAL CHECKLIST

1. Have the Flammable & Combustible liquid tank and associated systems and materials been submitted to the fire jurisdiction having authority for permit and approval?

Yes Submit evidence of application and approval by the fire jurisdiction having authority. Any work involving structural or electrical work must also be submitted by a registered design professional, along with the applicable review fees.

No Submit evidence of compliance to all applicable sections of the OBC, including Section 414.6, Ohio Fire Code Section 1301:7-7-34, and NFPA 30, 30A & 70. Any work involving Flammable & Combustible materials, structural or electrical work must be submitted by a registered design professional, along with the applicable review fees.

The following additional information shall be provided if answered “No” to Item 1 above:

- Provide tank manufacturer’s plans, cut sheets and specifications.
- Provide Flammable & Combustible Material Safety Data Sheets and material quantities.
- Indicate Power (NFPA 70) / Fuel (NFPA 30) shut-offs to appliances/ equipment (shut-off no less than 20’ and not more than 100’ from dispensing device).
- Show details of grounding systems.

2. Does the scope of work involve the installation and/or modification of a new Structural Support and/or electrical system?

_____ No (If no, please make note on the plans to this effect.)

_____ Yes (If yes, plans and specifications of this work must be provided from a registered Design professional, along with the applicable review fees.)

3. Indicate tank(s) and site structures/building locations with dimensions. Also, locate property lines, fences, containment, etc.