



# *The City of Lorain, Ohio*

## DEPARTMENT OF ENGINEERING

200 West Erie Avenue, 4<sup>th</sup> Floor City Hall  
Lorain, Ohio 44052 • Phone (440) 204-2003 • Fax (440) 204-2522

---

Dale Vandersommen, P.E.  
City Engineer

### ADDENDUM NO. 1

## BLACK RIVER DREDGED MATERIAL REUSE FACILITY ENTRANCE BUILDING PROJECT

### ATTENTION BIDDERS

All Bidders on the above titled Project are hereby advised of the following modifications to the original Contract Documents, which shall be incorporated into the Contract Documents for the Project. This Addendum takes precedence over any and all information previously issued. No other revisions to the Contract Documents are to be inferred.

Addendum No. 1 consists of 2 pages.

### CLARIFICATIONS

1. *Bid opening has been moved to 11:30AM, on Monday February 20<sup>th</sup>, 2023. Bids will still be submitted to the same location (Lorain City Hall, 4<sup>th</sup> Floor Engineering Office).*
2. *The selected bidder may be asked to provide a unit pricing structure defining and/or quantifying all-inclusive labor, equipment, and material rates. These will pertain to schedule activities such as but not limited to excavation volumes at depth intervals, utility installations, mechanical installations, and general labor. These values will be used for quantifying payment applications, schedule values, as well as any scope changes that may arise.*

### BID QUESTIONS AND RESPONSES

1. Question: What is the invert elevation for the new six-inch sanitary sewer at the manhole tie in?  
*Response: Sheet C-104 of the civil drawings calls for the new sanitary lateral to tie into the City of Lorain's Sanitary manhole no. 5864 at the manhole floor elevation of 607.34'. The rim elevation of this manhole is 626.25. The existing lateral servicing the subject City of Lorain property is tied into manhole no. 5864 at approximately 7 feet below the rim elevation. In lieu of tying into the manhole directly, the new sanitary lateral shall tie into the existing lateral just north of the concrete apron at manhole no. 5864.*

**PLEASE NOTE THAT ALL ADDENDA MUST BE ACKNOWLEDGED IN THE PROPOSAL ON PAGE 34.**

**REMINDER: BIDS ARE DUE FEBRUARY 20, 2023 AT 11:00AM AND MUST BE ADDRESSED TO THE CITY OF LORAIN ENGINEER'S OFFICE, CITY HALL 4<sup>TH</sup> FLOOR**

**OPENING OF BIDS WILL TAKE PLACE AT 11:30AM IN THE CITY OF LORAIN COUNCIL CHAMBERS, CITY HALL 1<sup>ST</sup> FLOOR**